

## Features

- **Approvals:** UL864 and FM 3010
- **Circuits:** Three initiation circuits as standard
- **Zones:** Any single zone or any combinations of zones can be configured to release
- **NAC Delay:** Configurable first stage NAC delays
- **Detection Delay:** Configurable detection delays
- **Manual Release:** Zero time delay upon manual release option
- **Indicators:** Supports up to seven, four wire status indicators
- **Fan Control:** Built in Extract Fan control
- **Compatibility:** Compatible with I.S. barriers
- **Zone Input:** Non-latching zone input option to receive signals from other systems such as aspirating equipment
- **Release Delay:** Configurable releasing delays up to 60 seconds in 5 second steps
- **Duration:** Configurable releasing duration up to 5 minutes in 5 second steps
- **Timer:** Countdown timer shows time remaining until release



## Description

The **LIFECO** releasing panel offers outstanding value and performance for all small to medium fixed firefighting installations.

With three initiating circuits as standard, release can be configured to activate from any combination of detection zone inputs to allow (among other combinations) any two from three types of activations for detection in ceiling void, room and floor void applications.

The extensive configuration options of the **LF-1810** allow the functionality of the system to be extensively modified. The panel contains a large LED display to enable easy configuration and control which also displays the time remaining until release for added user safety.

The countdown time is duplicated on up to seven remote status units to provide local indication of the system status.

With all the electronics mounted on a single, easily removable, steel plate **LF-1810** panels are both robust and easy to install.

## Panels

- **LF-1810-12:** Surface mounting panel - Red 115V (Size: 368 x 310 x 90 mm)
- **LF-1810-13:** Surface mounting panel - Red 230V (Size: 368 x 310 x 90 mm)

## Technical Specifications

- **Construction:** 1.2mm mild sheet steel
- **IP Rating:** IP30
- **Finish:** Epoxy powder coated
- **Colour-lid & box:** Red RAL 3002 (optional grey BS 00 A 05 semi-matt)
- **Mains Supply:** 230V AC or 115V AC
- **Mains Supply Fuse:** 1.6Amp (F1.6A L250V)
- **Power Supply Rating:** 3 Amps total including battery charge 28V +/- 2V
- **Maximum Ripple Current:** 200 millivolts

- **Battery Type (Yuasa NP):** Two 12 Volt 7Ah sealed lead acid in series
- **Battery Charge Voltage:** 27.6VDC nominal (temperature compensated)
- **Battery Charge Current:** 0.7A maximum
- **Battery Fuse:** 20mm, 3.15A glass
- **Maximum Current Draw from Batteries:** 3 amps
- **Quiescent Current of Panel in Mains Fail:** 0.095A
- **ROV Output:** Fused at 500mA with electronic fuse
- **Sounder Outputs:** 24V Fused at 500mA with electronic fuse
- **Fault Relay Contact Rating:** 30VDC 1A Amp maximum
- **Fire Relay Contact Rating:** 30VDC 1A Amp maximum
- **Local Fire Relay Contact Rating:** 30VDC 1A Amp maximum
- **First Stage Contact Rating:** 30VDC 1A Amp maximum
- **Second Stage Contact Rating:** 30VDC 1A Amp maximum
- **Extract Contact Rating:** 30VDC 1A Amp maximum
- **Zone Quiescent Current:** 2mA maximum
- **Terminal Capacity:** 12 AWG
- **Number of Detectors Per Zone:** Dependent on type (maximum 32)
- **NAC Rating:** 0.5A per circuit
- **Detection Circuit End of Line:** 6K8 5% 1/2 Watt resistor
- **Monitored Input End of Line:** 6K8 5% 1/2 Watt resistor
- **Sounder Circuit End of Line:** 10K 5% 1/4 Watt resistor
- **Extinguisher Output EOL:** 1N4004 Diode
- **No. of Initiating Circuits:** 3
- **No. of NAC Circuits:** 2 x 1st stage, 1 x 2nd stage
- **Extinguisher Release Output:** Fused at 1 Amp
- **Extinguisher Release Delay:** Adjustable 0 to 60 seconds (in 5 second steps)
- **Extinguisher Release Duration:** Adjustable 60 to 300 seconds (in 5 second steps)
- **SIL, AL, FLT, RST Inputs:** Switched -ve, max resistance 100 ohms
- **Zone Normal Threshold:** 8K ohms to 1k ohm
- **Detector Alarm Threshold:** 999 ohms to 400 ohms
- **Call Point Alarm Threshold:** 399 ohms to 100 ohms
- **Short Circuit Threshold:** 99 ohms to 0 ohms
- **Monitored Inputs Normal Threshold:** 8K ohms to 1k ohm
- **Monitored Inputs Alarm Threshold:** 999 ohms to 100 ohms
- **Monitored Inputs Short Circuit Threshold:** 99 ohms to 0 ohms
- **Status Unit/Ancillary Board Connection:** Two wire RS485 connection
- **Status Unit Power Output:** Fused at 500mA with electronic fuse

## Programmable Functions

Access Level 2

- **Test Zones:** Test Zones 1 to 3
- **Disable Zones:** Disable Zones 1 to 3
- **Disable Alarms:** Disable 1st stage alarms
- **Disable Relay 1:** Disable pre-activated 1st stage relay
- **Disable Relay 2:** Disable pre-activated 2nd stage relay
- **Disable Fan:** Disable extract fan output
- **Disable Input:** Disable manual release input



- **Disable Release:** Disable releasing sub system
- **Activate Fan:** Activate extract fan output
- **Activate Delays:** Activate alarm delays

Access Level 3

- **Sounder Delay:** Sounder delay
- **Coincidence:** Coincidence detection
- **Panel Features:** Disable panel features
- **Zone Delays (Detectors):** Zone alarm delays (detectors)
- **Zone Delays (Call Stations):** Zone alarm delay (call stations)
- **I.S. Barrier:** Configure zone for I.S. barrier use
- **Zone Short Circuit:** Zone short circuit alarm
- **Zone Latching:** Zone non latching
- **Input Delay:** Zone inputs delay
- **Release Delay:** Extinguisher release time delay
- **Duration Timer:** Extinguisher release duration timer
- **Reset Timer:** Extinguisher reset delay timer

### Connection Diagram

