

Certificate of Product Approval

Certificate Number: 1038BFa

Issue: 01

Lichfield Fire & Safety Equipment Co Ltd.

Unit 8, Calibre Industrial Park
Laches Close, Four Ashes
Wolverhampton
WV10 7DZ
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

'LIFECO' Fire Hose Reels

(Refer to attached appendix for details)

Standards

EN 671-1:2012

Fixed firefighting systems. Hose systems. Hose reels with semi-rigid hose

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Joe Milton

Verifier

1 September 2023

Date of Issue

1 September 2023

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1038BFa Lichfield Fire & Safety Equipment Co Ltd.

Issue: 01

'LIFECO' Fire Hose Reels to EN 671-1:2012

Product Name	Description	Hose Nominal Bore (mm)	Hose Maximum Length (m)	Nozzle type	LPCB Ref. No.
LF-MA19	Manual, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/01
LF-MA25	Manual, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/02
LF-AA19	Automatic, swinging arm, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/03
LF-AA25	Automatic, swinging arm, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/04
LF-MF19	Manual, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/06
LF-MF25	Manual, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/07
LF-MP19	Manual, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/08
LF-AP19	Automatic, swinging pipe, cabinet or wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/09
LF-MP25	Manual, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/10
LF-AP25	Automatic, swinging pipe, cabinet or wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/11
LF-AF19	Automatic, fixed, wall mounted	19	30	Lever operated jet only or rotary operated jet/spray	1038BFa/17
LF-AF25	Automatic, fixed, wall mounted	25	30	Lever operated jet only or rotary operated jet/spray	1038BFa/19

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for BRE Global Ltd.

Joe Milton

Verifier

1 September 2023

Date of Issue

1 September 2023

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre