

Kitemark™ Certificate

This is to certify that:

Lichfield Fire & Safety Equipment FZE
P.O. Box 18650, Jebel Ali Free Zone,
Dubai
United Arab Emirates

Holds Certificate Number:

KM 817861

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



Shahm Barhom, Group Product Certification Director

For and on behalf of BSI:

First Issued: 2025-02-10

Effective Date: 2025-02-10

Latest Issue: 2025-02-10

Expiry Date: 2028-02-09

Page: 1 of 3



This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 817861

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
LF-PDP-1	1 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 8A & 34B	JD-MFZ1-00 Revision 03 Dated 2021.10.18	30285764
LF-PDP-2	2 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 13A & 55B	JD-MFZ2-00 Revision 02 Dated 2018-09-05	30285764
LF-PDP-4	4 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 21A & 113B	JD-MFZ4-00 Revision 03 Dated 2021.10.18	30285764
LF-PDP-6	6 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 34A & 183B	JD-MFZ6-00 Revision 02 Dated 2018-09-05	30285764
LF-PDP-9	9 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 43A & 233B	JD-MFZ9-00 Revision 02 Dated 2018-09-05	30285764
LF-PDP-12	12 kg, ABC 40% powder, stored pressure. Temperature range: -30°C to +60 °C Working pressure: 14 bar Fire ratings: 55A & 233B	JD-MFZ12-00 Revision 03 Dated 2021.10.18	30285764
LF-PW-2	2 litre, water + additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire ratings: 13A, 34B & 25F	JD-FX2-00 Revision 02 Dated 2021.12.08	30285764

First Issued: 2025-02-10

Latest Issue: 2025-02-10

Effective Date: 2025-02-10

Expiry Date: 2028-02-09

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 817861

Model No	Description	GA Drawing Reference, Revision & Date	Technical File Review
LF-PW-6	6 litre, water + additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire ratings: 34A, 113B & 75F	JD-FX6-00 Revision 02 Dated 2020.12.08	30285764
LF-PW-9	9 litre, water + additive, stored pressure. Temperature range: -15°C to +60 °C Working pressure: 12 bar Fire ratings: 55A, 183B & 75F	JD-FX9-00 Revision 02 Dated 2020.12.08	30285764
LF-PF-2	2 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire ratings: 5A & 34B	JD-MPZ2-00 Revision 02 Dated 2020.12.08	30285764
LF-PF-6	6 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire rating: 13A	JD-MPZ6-00 Revision 02 Dated 2020.12.08	30285764
LF-PF-9	9 litre, 3% AFFF foam, stored pressure. Temperature range: +5°C to +60 °C Working pressure: 12 bar Fire rating: 21A	JD-MPZ9-00 Revision 02 Dated 2020.12.08	30285764
LF-CO-2	2 kg, carbon dioxide, alloy steel. Temperature range: -30°C to +60 °C Fire rating: 34B	JD-MT2A-00 Revision 05 Dated 2022.06.29	30285764
LF-CO-5	5 kg, carbon dioxide, alloy steel. Temperature range: -20°C to +60 °C Fire rating: 89B	JD-MT5A-00 Revision 05 Dated 2022.06.29	30285764

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2025-02-10

Latest Issue: 2025-02-10

Effective Date: 2025-02-10

Expiry Date: 2028-02-09

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).