



Sprinkler System Components | Branch Line Alarm Testers | **Sprinkler System Alarm Testers**

LF-TND

Product Description

Product Specification

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
LF-TND	1	(25)	5.6	300	(2065)	a, b, c
LF-TND	1 1/4	(32)	5.6	300	(2065)	a, c
LF-TND	1 1/2	(40)	5.6	300	(2065)	a, c
LF-TND	2	(50)	5.6	300	(2065)	a, b, c

Remarks:

- a. Available with female NPT connections.
- b. Available with grooved connections.
- c. Available with female threaded BSP connections.

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Lichfield Fire & Safety Equipment Co Ltd
 Unit 8 Calibre Industrial Park,
 Laches Close, Four Ashes,
 Wolverhampton, Staffordshire
 WV10 7DZ
<http://lifeco-uk.com>