

Model LF-DIPA

File Number: EX6091

COMPANY

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

Edmund House
12-22 Newhall Street
Birmingham, B3 3AS United Kingdom

MODEL INFO

LF-DIPA

GENERAL

Sprinkler System Type	Body Type	Nominal Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Trim Configuration Type	Installed Position
Deluge sprinkler system	--	2, 3, 4, 6, 8	Flanged, Grooved	250 (1723)	Dry pilot line, Wet pilot line, Electric actuation, manual release	Vertical, Horizontal
Preaction sprinkler system	--	2, 3, 4, 6, 8	Flanged, Grooved	250 (1723)	Single interlock w/ electric actuation, Single interlock w/ pneumatic actuation, Single interlock w/ wet pilot release Double interlock w/ electric-pneumatic actuation, Double interlock w/ electric-electric actuation	Vertical, Horizontal

NOTES

Additional Model Notes

Deluge valve trims include model ET-D, ETD-T, ETD-D, ET-W, ETW-T, ETW-D, NT-D, NT-W. MODEL MR, MR1 and MR5 Manual Release Station, Model PSV1 and PSV5 Priming Shut-off Valve, PRD1 Pneumatic Release Device, Model DPA-H1, DPA-H2, DPA-H3 and DPA-H5 Dry Pilot Actuator.

GENERAL

Installation Limitations

End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

For accessories used with these valves, see certifications under Accessories for Special Systems (VLTR).

All trim configuration types shall include a manual release. Height of pilot line above valve limited as shown in the installation instructions.

Report Date: 2021-12-29

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."