

CERTIFICATE OF COMPLIANCE

Certificate Number 20220211-EX6091
Report Reference EX6091
Issue Date 2022-February-11

Issued to: LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD
UNIT 8, CALIBRE INDUSTRIAL PARK
LACHES CLOSE FOUR ASHES
WOLVERHAMPTON, WV10 7DZ United Kingdom

This certificate confirms that representative samples of Special System Water Control Valves, Deluge Type

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 260, "Dry Pipe and Deluge Valves for Fire-Protection Service."

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

See addendum page 2.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20220211-EX6091
Report Reference EX6091
Issue Date 2022-February-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model A, 2, 3, 4, 6 and 8 in. sizes, deluge valves for vertical installation only with a rated pressure of 175 psig. For operation by dry pilot line, manually, electrically or wet pilot line of sprinklers. Height of pilot line above valve limited as shown in the Installation Instructions. For accessories used with these valves, see listing under "Accessories for Special Systems".

Pre-Action and Deluge (Wet and Dry Pilot) valve, Model LF-DV100A, 100A 4 in. size, vertical installation.

Pre-Action and Deluge (Wet and Dry Pilot) valve, Model LF-DV150A, 150A 6 in. size, vertical installation.

Models LF-DIPA - 2, 3, 4, 6 and 8 in. sizes, deluge valves rated 250 psig for use with Single Interlock Preaction w/ electric release, Single Interlock Preaction w/ pneumatic release, Single Interlock Preaction w/ Wet pilot release, Double Interlock Preaction w/ electric / electric release and Double Interlock Preaction w/ electric/pneumatic release, installed in accordance with the manufacturer's installation instructions. For accessories used with these valves, see Listing under "Accessories For Special Systems."

Trademark and/or Tradename: , "LIFECO"



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

