



GSZN.R38445 - Swinging-type Fire Doors, Positive-pressure Tested

Swinging-type Fire Doors, Positive-pressure Tested

See General Information for Swinging-type Fire Doors, Positive-pressure Tested

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

R38445

UNIT 8, CALIBRE INDUSTRIAL PARK
 LACHES CLOSE FOUR ASHES
 WOLVERHAMPTON, WV10 7DZ UNITED KINGDOM

Swinging doors may be provided as follows:

Model	Max. Rating	Door Type	Opening Type	Category	Min Size ft-in(mm)		Max Size ft-in(mm)		Latching Hardware	Accessories [*]	Temp Rise Rating °F(°C)	Smoke Control
					W	H	W	H				
-	3 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Fire Door Viewer, Glazing, Louver	450 (250)	S
-	1 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Fire Door Viewer, Glazing, Louver	450 (250)	S
	1 hour	Hollow-Metal (Steel	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Mortise Fire Exit, Rim Exit	Fire Door Viewer, Glazing	450 (250)	S

		Stiffened)										
	1 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Cylindrical, Mortise	Fire Door Viewer, Glazing, Louver	450 (250)	S
	1 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Mortise Fire Exit, Surface Vertical Rod Exit	Fire Door Viewer, Glazing	450 (250)	S
-	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	450 (250)	-
	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod Exit	Auxiliary Locks, Fire Door Viewer, Glazing	450 (250)	-
	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	450 (250)	-
	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod	Auxiliary Locks, Fire Door Viewer, Glazing	450 (250)	-

									Exit			
-	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	-	-
	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod Exit	Auxiliary Locks, Fire Door Viewer, Glazing	-	-
	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	-	-
	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod Exit	Auxiliary Locks, Fire Door Viewer, Glazing	-	-
-	3 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Fire Door Viewer, Glazing, Louver	450 (250)	S
	3 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Mortise Fire Exit, Rim Exit	Fire Door Viewer, Glazing	450 (250)	S

		Stiffened)										
-	1 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Cylindrical, Mortise	Fire Door Viewer, Glazing, Louver	450 (250)	S
	1 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Mortise Fire Exit, Surface Vertical Rod Exit	Fire Door Viewer, Glazing	450 (250)	S
-	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	450 (250)	-
	2 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	3 - 7 (1092)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod Exit	Auxiliary Locks, Fire Door Viewer, Glazing	450 (250)	-
-	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Cylindrical, Mortise	Auxiliary Locks, Fire Door Viewer, Glazing, Louver	-	-
	2 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	7 - 3 (2210)	7 - 3 (2210)	Concealed Vertical Rod Exit, Mortise Fire Exit, Rim Exit, Surface Vertical Rod	Auxiliary Locks, Fire Door Viewer, Glazing	-	-

-	3 hour	Hollow-Metal (Steel Stiffened)	Pair w/ Astragal	A	-	-	9 - 6.099999999999999 (2898)	9 - 8.099999999999999 (2949)	Electrically-controlled Single-point, Mortise, Mortise Fire Exit, Mortise w/ Auxiliary Locks, Rim Exit	Auxiliary Locks, Cladding, Concealed Closer, Fire Door Coordinator, Fire Door Viewer, Glazing, Louver	-	-
	3 hour	Hollow-Metal (Steel Stiffened)	Single	A	-	-	4 - 0.25 (1226)	9 - 8.099999999999999 (2949)	Cylindrical, Mortise, Mortise Fire Exit, Mortise w/ Auxiliary Locks, Rim Exit	Auxiliary Locks, Cladding, Concealed Closer, Fire Door Viewer, Glazing, Louver	-	-

[*] - Additional information regarding accessories can be found under the Guide Card GSZN

Trademark and/or Tradename:



Last Updated on 2020-04-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"