

VLFT.EX6091 - Special System Water Control Valves, Deluge Type

Special System Water Control Valves, Deluge Type

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

UNIT 8, CALIBRE INDUSTRIAL PARK

LACHES CLOSE FOUR ASHES

WOLVERHAMPTON, WV10 7DZ United Kingdom


EX6091

Model A, 2, 3, 4, 6 and 8 in. sizes, deluge valves for vertical installation only with a rated pressure of 175 psig. For operation by dry pilot line, manually, electrically or wet pilot line of sprinklers. Height of pilot line above valve limited as shown in the Installation Instructions. For accessories used with these valves, see listing under "Accessories for Special Systems".

Pre-Action and Deluge (Wet and Dry Pilot) valve, Model LF-DV100A, 100A 4 in. size, vertical installation.

Pre-Action and Deluge (Wet and Dry Pilot) valve, Model LF-DV150A, 150A 6 in. size, vertical installation.

Models LF-DIPA - 2, 3, 4, 6 and 8 in. sizes, deluge valves rated 250 psig for use with Single Interlock Preaction w/ electric release, Single Interlock Preaction w/ pneumatic release, Single Interlock Preaction w/ Wet pilot release, Double Interlock Preaction w/ electric / electric release and Double Interlock Preaction w/ electric/pneumatic release, installed in accordance with the manufacturer's installation instructions. For accessories used with these valves, see Listing under "Accessories For Special Systems."

Trademark and/or Tradename:  , "LIFECO"

Last Updated on 2021-12-31

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"