UQGS.S24977 Heat-automatic Fire Detectors

Page Bottom

Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

LICHFIELD FIRE & SAFETY EQUIPMENTS CO LTD

S24977

UNIT 8, CALIBRE INDUSTRIAL PARK LACHES CLOSE FOUR ASHES WOVERHAMPTON, WV10 7DZ UNITED KINGDOM

					Spacing (Ft)	
Model No.	Туре	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Smooth Ceiling	to Wall or Partition
LE-ATG-EA	FT	None	-	135-150	70	25
LE-ATJ-EA	FT/ROR	None	-	135-194	70	35
LE-DCD-135	FT/ROR	None	NO	135	70	25
LE-DCD-190	FT/ROR	None	NO	190	70	25
LE-DFE-135	FT	None	NO	190	50	25
LE-DFE-190	FT	None	NO	190	50	25
LE-DSC-EA	FT, ROR	None	NO	190	50	25

*2 - D

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

ROR - Rate of rise

Last Updated on 2015-02-09

<u>Questions?</u> <u>Print this page</u> <u>Terms of Use</u> <u>Page Top</u>

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the <u>UL Environment database</u> for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".