

UQGS.S24977 - Heat-automatic Fire Detectors

Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD
 UNIT 8, CALIBRE INDUSTRIAL PARK
 LACHES CLOSE FOUR ASHES
 WOLVERHAMPTON, WV10 7DZ UNITED KINGDOM

S24977

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
LE-ATG-EA	FT	None	-	135-150	70	25
LE-ATJ-EA	FT/ROR	None	-	135-194	70	35
LE-DCD-135	FT/ROR	None	NO	135	70	25
LE-DCD-190	FT/ROR	None	NO	190	70	25
LE-DFE-135	FT	None	NO	190	50	25
LE-DFE-190	FT	None	NO	190	50	25
LE-DSC-EA	FT, ROR	None	NO	190	50	25

*2 - D

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

ROR - Rate of rise

Trademark and/or Tradename: "LIFECO", 

Last Updated on 2020-04-27

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2022 UL LLC."