

EN 54 Part 5: Point-type Heat Detectors

COMPANY

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD
UNIT 8, CALIBRE INDUSTRIAL PARK
LACHES CLOSE FOUR ASHES
WOLVERHAMPTON, WV10 7DZ United Kingdom

S36443

Model No.	Communication	Alarm Temp Rating, °C	Class	Suffix
Rate of Rise Point Type Heat Detector				
LF-F50R	Conventional	60	A2	R
Fixed Temperature Point Type Heat Detector				
LF-F50	Conventional	65	A2	S
Rate of Rise Point Type Heat Detector				
LF-FS50	Conventional	60	A2	R

[CLICK HERE TO VIEW THE UL-EU-01290-EN CERTIFICATE](#)
[CLICK HERE TO VIEW THE UL-EU-01293-EN CERTIFICATE](#)

Last Updated on 2023-12-01

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."