

Extinguishing System Attachments

COMPANY

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

UNIT 8, CALIBRE INDUSTRIAL PARK

LACHES CLOSE FOUR ASHES

WOLVERHAMPTON, WV10 7DZ United Kingdom

S35796

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet Pipe, Paddle Type


Model	Size In.	Pipe Schedule	Max System Pressure psig
LF-JZL-50	2	10 thru 40	175
LF-JZL-65	2.5	10 thru 40	450
LF-JZL-80	3	10 thru 40	450
LF-JZL-100	4	10 thru 40	450
LF-JZL-125	5	10 thru 40	450
LF-JZL-150	6	10 thru 40	450
LF-JZL-200	8	10 thru 40	450
LF-WFS-450	2.0	10 thru 40	450
LF-WFS-450	2.5	10 thru 40	450
LF-WFS-450	3	10 thru 40	450
LF-WFS-450	4	10 thru 40	450
LF-WFS-450	5	10 thru 40	450
LF-WFS-450	6	10 thru 40	450
LF-WFS-450	8	10 thru 40	300

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

Model	Oper Pressure psig	Max System Pressure psig
LF-SSOSY-1	N/A	N/A
LF-SSOSY-2	N/A	N/A

LF-SSOSY-3	N/A	N/A
LF-SIP-1	N/A	N/A
LF-SIP-2	N/A	N/A
LF-SIP-3	N/A	N/A

Marking: Trademark and/or Tradename , "LIFECO"

Last Updated on 2023-10-23

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."