

Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

LF621

Details

Category	Non-Storage Sprinklers
Class of Work	2017 - AS, Control Mode, Pendent
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Type	Pendent
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Chrome, Brass
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
Listing Country	United Kingdom

Company

Lichfield Fire & Safety
Equipment Co Ltd
Unit 8 Calibre Industrial Park,
Laches Close, Four Ashes,
Wolverhampton, Staffordshire
WV10 7DZ
<http://lifeco-uk.com>