



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
LF610	5.6	Upright	SR	5 mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
LF611	5.6	Upright	QR	3 mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

Lichfield Fire & Safety Equipment Co Ltd
Unit 8 Calibre Industrial Pk, Laches Close, Four Ashes,
Wolverhampton, Staffordshire WV10 7DZ, United Kingdom

FM Approvals Class: 2016

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR469545

Approval Granted: 13 June 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA





Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
LF620	5.6	Pendent	SR	5 mm	1/2	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
LF621	5.6	Pendent	QR	3 mm	1/2	Brass, Chrome	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

Lichfield Fire & Safety Equipment Co Ltd
Unit 8 Calibre Industrial Pk, Laches Close, Four Ashes,
Wolverhampton, Staffordshire WV10 7DZ, United Kingdom

FM Approvals Class: 2017

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR469545

Approval Granted: 13 June 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA



Member of the FM Global Group





Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
LF640	5.6	Horizontal Sidewall	SR	5 mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)
LF641	5.6	Horizontal Sidewall	QR	3 mm	1/2	Brass, Chrome, Polyester	135, 155, 175, 200, 286 (57, 68, 79, 93, 141)

Prepared for:

Lichfield Fire & Safety Equipment Co Ltd
Unit 8 Calibre Industrial Pk, Laches Close, Four Ashes,
Wolverhampton, Staffordshire WV10 7DZ, United Kingdom

FM Approvals Class: 2012

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR469545

Approval Granted: 13 June 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062
USA

