

System Unit LIFECO-FK5112, FK-5-1-12 engineered extinguishing system units, 25 bar

File Number: EX15998

COMPANY

LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

Edmund House
12-22 Newhall Street
Birmingham, B3 3AS United Kingdom

SYSTEM UNIT INFO

LIFECO-FK5112, FK-5-1-12 engineered extinguishing system units, 25 bar
Engineered, Halocarbon

CLEAN AGENT EXTINGUISHING SYSTEM UNITS	VALUE
Extinguishing Agent (ASHRAE Designation)	FK-5-1-12

MANUALS AND BULLETINS		
Part No.	Description	Date/Rev
LF5112MAL-0001	Installation, Design and Maintenance Manual	Rev. 08 dated 2024-03

SYSTEM UNIT INFORMATION		
Operating Pressure at Temperature	Minimum Operating Temperature	Maximum Operating Temperature
25 bar at 21 °C (360 psig at 70 °F)	0 C (32 F)	50 C (122 F)

THESE INSTALLATIONS REQUIRE THE USE OF THE LISTEE'S FLOW CALCULATION SOFTWARE:
Software Name/Version
LIFECO-UK Clean Agent Flow Calculation Software v4.00 (FK-5-1-12)



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."