

# Certificate of Compliance

**Certificate Number:**  
E546099

**Report Reference:**  
E546099-20250319

**Issue Date:**  
2025-03-19

Issued to:

**LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD**  
**Edmund House**  
**12-22 Newhall Street Birmingham B3 3AS**  
**United Kingdom**

This certificate confirms that representative samples of:

REACTION TO FIRE AND FIRE RESISTANCE OF CABLES EVALUATED IN ACCORDANCE WITH INTERNATIONAL STANDARDS

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**EN 50200:2015, Method of test for resistance to fire of unprotected small cables for use in emergency circuits**

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch  
UL Mark Certification Program Owner

# Certificate of Compliance

**Certificate Number:** E546099  
**Report Reference:** E546099-20250319  
**Issue Date:** 2025-03-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Products Covered	Product Designation	Nomenclature
	2 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	
	3 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	
	4 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor	



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# Reaction to Fire and Fire Resistance of Cables Evaluated in accordance with International Standards

## COMPANY

### LICHFIELD FIRE & SAFETY EQUIPMENT CO LTD

Edmund House  
12-22 Newhall Street  
Birmingham, B3 3AS United Kingdom

E546099

*View model for additional information*

Model(s): [2 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor](#)

Model(s): [3 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor](#)

Model(s): [4 Core 1 mm2 to 2.5 mm2 Cu/Silicone/ PET tape/ TC Drain wire/Al Foil Screened/Polyolefin sheathed Cable with Class 1 conductor](#)

Last Updated on 2025-03-19

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."