

Valves | Water Control Valves (OS&Y and NRS Gate Valves) | **Gate Valves, Outside Screw and Yoke**

Models 3299-365-FFLF, 3299-365-FGLF, 3299-365-GGLF, 3299-365-JJLF, & 3299-365-FJLF

Product Description

Resilient Seated Gate Valves. Available with the following sizes, end connections and rated working pressures:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
3299-365-FFLF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Flange × Flange (a)
3299-365-FGLF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Flange × Groove (a, b)
3299-365-FJLF	3, 4, 6, 8, 10, 12	(80, 100, 150, 200, 250, 300)	365	(2515)	Flange × Mechanical Joint (a, c)
3299-365-GGLF	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Groove x Groove (b)
3299-365-JJLF	3, 4, 6, 8, 10, 12	(80, 100, 150, 200, 250, 300)	365	(2515)	Mechanical Joint x Mechanical Joint (c)

a. Flange Connections are ANSI 125/150, EN1092, AS4087

b. Groove Connections are AWWA C606

c. Mechanical Joint Connections are AWWA C153/A21.11-2007

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)

Company

Lichfield Fire & Safety Equipment Co Ltd
 Unit 8 Calibre Industrial Park,
 Laches Close, Four Ashes,
 Wolverhampton, Staffordshire
 WV10 7DZ
<http://lifeco-uk.com>

FM Approvals

Certification Type	FM Approved
Listing Country	United Kingdom